

	Before the conflict (three months)		During the conflict(2020-2022)		Post conflict (Six months)	
Feeder line	Freq.t Interruptions , F/ day	Interruption durations, D (Hr)/day	Freq.t Interruptions , F/ day	Interruption durations, D (Hr)/day	Freq.t Interruptions , F/ day	Interruption durations, D (Hr)/day
K-04	2.59	1.62	1.36	7.56	3.37	1.65
K-06	1.49	0.93	0.62	6.40	1.89	1.50

Customer-Oriented Reliability Indices	3_months before the conflict	2020 (9 months during the conflict)	2021(during the conflict)	2022 (9 months during the conflict)	6 months post conflict
SAIDI (Hour/Customer/year)	134.16	1,455.51	557.42	2,866.29	162.14
SAIFI (Interruption/Customer)	0.6045	0.5632	0.8697	0.6671	0.8502
CAIDI (Hour/Interruption)	221.9	2,584.357	640.93	4,296.64	190.708
EENS (MWh) for both feeders	39.52	7,595.98	208.0	23,637.57	47.78